



GENERAL NOTES:

- A. CONCEALED CABLE TRAY INSTALLED ABOVE CEILING TILE DOES NOT REQUIRE BOTTOM TRAY AND TOP COVER FITTINGS. PROVIDE TRAY AND COVER FOR EXPOSED CABLE TRAY ONLY.
- B. SUPPORT CABLES FROM CABLE TRAY TO 1" CONDUIT STUB OF OUTLET BOX WITH J-HOOKS ABOVE SUSPENDED CEILING. INSTALL J-HOOKS ON 48" CENTERS.
- C. PROVIDE MINIMUM OF 1" SLEEVED PENETRATION OF WALLS EXTENDING TO OVERHEAD STRUCTURE WHERE REQUIRED FOR ROUTING CABLE TO OUTLET BOXES. PROVIDE 1" SLEEVE FOR EACH OUTLET BOX SERVED.
- D. WORK OF DIVISIONS 27 AND 28 IS SHOWN ON THIS DRAWING.

SHEET NOTES:

- 1. EXPOSED 3-4" CONDUITS DOWN FROM ABOVE SUSPENDED CEILING TO FLOOR BELOW. FIRESTOP FLOOR PENETRATIONS. PAINT CONDUIT AND SUPPORTS TO MATCH WALL. BOND ALL CONDUITS TOGETHER.
- 2. EXPOSED 1-4" CONDUIT TO CABLE TRAY IN CORRIDOR. BOND CONDUIT TO CABLE TRAY. DO NOT ROUTE ABOVE ELECTRICAL PANELBOARD.
- 3. 12" WIDE X 2" HIGH WIRE MESH CABLE TRAY ABOVE SUSPENDED CEILING. INSTALL ALONG FULL LENGTH OF CORRIDOR AS SHOWN AND SUPPORT ON WALL AT BOTH ENDS. PROVIDE DIAGONAL SUPPORTS AS REQUIRED TO RESTRICT LATERAL SWAY.
- 4. OUTLET FOR WALL MOUNTED TELEPHONE. OWNER TO PROVIDE INSTRUMENT. PROVIDE 1 CAT-6 CABLE AND INSTALL FACE PLATE AT 48" A.F.F.
- 5. OUTLET FOR HORIZONTAL COMMUNICATIONS CABLEING TO WORK AREA. DOUBLE GANG BOX WITH SINGLE GANG MUD RING AND 1" CONDUIT STUB UP TO ACCESSIBLE VOID ABOVE CEILING. 3 CAT-6 CABLES FROM TELECOMMUNICATIONS ROOM G07.
- 6. FLUSH MOUNT OUTLETS UNDER COUNTER IN FRAME WALL.
- 7. PROVIDE DURESS ON UNDERSIDE OF COUNTER WITHIN REACH OF SEATED PERSON AT COUNTER. CABLE TO PANEL IN ROOM G07.

SECOND FLOOR
1TELECOMMUNICATIONS PLAN

95% SUBMISSION



C.W. MOORE PLAZA
250 S. 6TH ST. - BOISE, ID 83702
(208) 343-4835 - FAX (208) 343-1858
http://www.cshq.com

AMY E. DOCKTER, P.E.
C.W. MOORE PLAZA
250 S. 6TH ST.
BOISE, IDAHO
PHONE: 208-343-4835 FAX: 208-343-1858

THESE DRAWINGS AND SPECIFICATIONS, AS INSTRUMENTS OF SERVICE, ARE AND SHALL REMAIN THE PROPERTY OF THE ARCHITECT / ENGINEER. NO PART OF THESE DRAWINGS OR SPECIFICATIONS SHALL BE REPRODUCED OR USED IN ANY MANNER OR FOR ANY OTHER PROJECTS WITHOUT THE WRITTEN CONSENT OF CSHQ OR ITS AFFILIATES. Copyright 1991

PRELIMINARY
NOT FOR
CONSTRUCTION

DRAWING TITLE
SECOND FLOOR
TELECOMMUNICATIONS PLAN

APPROVED: DIVISION CHIEF

APPROVED: SERVICE DIRECTOR

PROJECT TITLE
VAMC
RENOVATE
BUILDING 33

BUILDING NUMBER
33

CHECKED
AKD

DRAWN
JDR

LOCATION
BOISE, IDAHO

DATE
03/04/11

PROJECT NO.
531-10-114

DRAWING NO.
E2.10

DWG. 91 OF 102

